

Rack System Install & Proper Pillow Filter Install Instructions (4" & 7" Systems)



Locate area under drain where rack needs installed. **TIP:** Install system as high and close to drain as possible to help ensure grease goes into rack.



Center mounting bracket under drain, height in generally approx. 2" below the fan base. **TIP:** Place 1st screw into center upper hole then install **ALL** screws.



Center "deflector shield" just above mounting bracket and secure in place with provided screws.



Test fit rack by placing the back top edge 1st into the mounting bracket.



If rack sits uneven, simply remove rack and adjust the feet up or down as needed to level system.



Lay filter out flat and use your hands to evenly spread filter media.



Place filter on top of rack as shown so all corner over hang the system.



Tuck all corners of the filter into rack.



CRITICAL STEP!

With filter now in place use your hands to "bowl out" the middle of the filter. This allows the filter to fill evenly from the middle out.



CRITICAL STEP!

Ensure the drain hole has filter media in front of it, failure to do so may result in unfiltered liquids to leak from system.



If installing a multi filter system (7", 10" or Supreme), place 1st filter in then move to installing 2nd filter in the exact same manner.



Place 2nd filter into the system, tucking the corners and "bowl out" the middle of the filter then replace the lid secured by lid latches.

Tools Needed/ Install Tips: Power Drill, 3/8" Nut Driver

Caution: Use gloves as metal edges sharp, Wear eye protection